

CERTIFICATE

(1) EU-Type Examination

(2) **Equipment or protective systems intended for use in potentially explosive atmospheres - Directive 2014/34/EU**

(3) EU-Type Examination Certificate Number: **KEMA 00ATEX2006 X** Issue Number: **6**

(4) Product: **Electronic Beacons, Types BExBG05D(-P)(-SIL), BExBG10D(-P)(-SIL), BExBG15D(-P)(-SIL), BExBG21D(-P), BExTBG05D(-P), BExBGL1D and BExBGL2D**

(5) Manufacturer: **European Safety Systems Ltd.**

(6) Address: **Impress House, Mansell Road, London W3 7QH, United Kingdom**

(7) This product and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

(8) DEKRA Certification B.V., Notified Body number 0344 in accordance with Article 17 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this product has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of products intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential test report number NL/KEM/ExTR10.0005/04.

(9) Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN 60079-0 : 2012 + A11 : 2013 EN 60079-1 : 2014 EN 60079-31 : 2014
EN IEC 60079-0 : 2018

except in respect of those requirements listed at item 18 of the Schedule.

(10) If the sign "X" is placed after the certificate number, it indicates that the product is subject to the Specific Conditions of Use specified in the schedule to this certificate.

(11) This EU-Type Examination Certificate relates only to the design and construction of the specified product. Further requirements of the Directive apply to the manufacturing process and supply of this product. These are not covered by this certificate.


(12) The marking of the product shall include the following:



II 2 G Ex db IIC T6...T3 Gb
II 2 D Ex tb IIIC T60 °C...T200 °C Db

Date of certification: 7 March 2019

DEKRA Certification B.V.



L.G. van Schie
 Certification Manager

Page 1/3



© Integral publication of this certificate and adjoining reports is allowed. This Certificate may only be reproduced in its entirety and without any change.

(13) **SCHEDULE**

(14) **to EU-Type Examination Certificate KEMA 00ATEX2006 X**

Issue No. 6

(15) **Description**

Electronic Beacons, Types BExBG05D(-P)(-SIL), BExBG10D(-P)(-SIL), BExBG15D(-P)(-SIL), BExBG21D(-P), BExTBG05D(-P), BExBGL1D and BExBGL2D, housed in aluminium enclosures in type of protection flameproof enclosure “db” and dust ignition protection by enclosure “tb”, are used to provide visual warning signals.

The Beacons are provided with a glass dome.
LED Beacon Types BExBGL1D and BExBGL2D are provided with a plastic dome cover.
Other Beacons are optionally provided with a plastic dome cover indicated by the suffix -P to the type designation; e.g. BExBG21D-P.

Electronic Beacons, Types BExBG05D, BExBG10D and BExBG15D, with a supply voltage of 24 Vdc have an optional monitoring module. For these the type designation is extended with –SIL.

The enclosure provides a degree of protection of IP66/IP67 per EN 60529.

For details about electrical and thermal data and marking see Annex 1 to this certificate.

Installation instructions

The instructions provided with the product shall be followed in detail to assure safe operation.

(16) **Report Number**

No. NL/KEM/ExTR10.0005/04.

(17) **Specific conditions of use**

The enclosure may generate an ignition-capable level of electrostatic charges under certain extreme conditions. The user should ensure that the equipment is not installed in a location where it may be subjected to external conditions that might cause a build-up of electrostatic charges on non-conducting surfaces.

Flameproof joints are not intended to be repaired.

(18) **Essential Health and Safety Requirements**

Covered by the standards listed at (9).

(19) **Test documentation**

As listed in Test Report No. NL/KEM/ExTR10.0005/04.

(13) **SCHEDULE**

(14) **to EU-Type Examination Certificate KEMA 00ATEX2006 X** Issue No. 6

(20) **Certificate history**

- | | | | |
|----------|---|-----------|--|
| Issue 1 | - | 6410100 | Initial certificate |
| Addendum | - | 209011400 | Change of potting material used in the line-bushing of the EEx de versions
Increase of the ambient temperature to +70 °C for all types
Removal of the prismatic lens of the non-LED versions |
| Addendum | - | 211859300 | Addition of Electronic Beacon Type BExBG21D |
| Issue 2 | - | 212737000 | Assessment in accordance with newer edition of standards:
EN 60079-0 : 2006, EN 60079-1 : 2007, EN 60079-7 : 2003,
EN 61241-0 : 2006 and EN 61241-1 : 2004 |
| Issue 3 | - | 218205100 | Addition of optional monitoring module to the 24 V Beacon types,
designation: ..-SIL |
| Issue 4 | - | 216785200 | Assessment in accordance with newer edition of standards:
EN 60079-0 : 2012, EN 60079-1 : 2007 and EN 60079-31 : 2014
Addition of new product variants BExBG05D-P, BExBG10D-P,
BExBG15D-P, BExBG21D-P, BExTBG05D-P, BExBG05D-P-SIL,
BExBG10D-P-SIL and BExBG15D-P-SIL with plastic lens cover
Removal of Ex e certified types |
| Issue 5 | - | 510005300 | Addition of new product Types BExBGL2D and BExCS110-L2D |
| Issue 6 | - | 510023100 | Assessment in accordance with newer edition of standards:
EN IEC 60079-0 : 2018 and EN 60079-1 : 2014 |

Annex 1 to: Certificate of Conformity IECEx DEK 10.0002X
EU-Type Examination Certificate KEMA 00ATEX2006 X, Issue 6
Report NL/KEM/ExTR10.0005/04

Electrical data

Beacon type	Supply voltage	Voltage range	Supply current	..-SIL types
BExBG05D(-SIL) BExBG05D-P(-SIL)	12 / 24 / 48 Vdc or 115 / 230 Vac	-	750 / 300 / 180 mA or 140 / 55 mA	24 Vdc – 325 mA
BExBG10D(-SIL) BExBG10D-P(-SIL)	12 / 24 / 48 Vdc or 115 / 230 Vac	-	1.45 A / 660 mA / 340 mA or 250 / 110 mA	24 Vdc – 685 mA
BExBG15D(-SIL) BExBG15D-P(-SIL)	24 / 48 Vdc or 115 / 230 Vac	-	860 / 480 mA or 360 / 170 mA	24 Vdc – 885 mA
BExTBG05D, BExTBG05D-P	115 / 230 Vac	-	140 / 55 mA	N/A
BExBGL1D	10-50 Vdc or 10-35 Vac or 115 / 230 Vac	-	400 mA (24 Vdc) or 812 mA (20 Vac) or 135 / 65 mA	N/A
BExBG21D, BExBG21D-P	24 / 48 Vdc or 115 / 230 Vac	-	1.2 A / 600 mA or 560 / 280 mA	N/A
BExBGL2D	24 Vdc or 115 / 230 Vac	18-54 Vdc or 103.5-126 Vac / 207-253 Vac	240 mA or 85 mA / 48 mA	N/A

Marking and temperature ratings

The relation between the electronic beacons, the ambient temperature range and the marking for gas and dust applications is given in the tables below.

GAS						
Ambient temp.	-50 °C to +40 °C	-50 °C to +45 °C	-50 °C to +50 °C	-50 °C to +55 °C	-50 °C to +60 °C	-50 °C to +70 °C
BExBG05D(-SIL)	Ex db IIC T6 Gb			Ex db IIC T5 Gb		Ex db IIC T4 Gb
BExBG10D(-SIL)	Ex db IIC T5 Gb					Ex db IIC T4 Gb
BExBG15D(-SIL)	Ex db IIC T5 Gb					Ex db IIC T4 Gb
BExBG21D				Ex db IIC T4 Gb		Ex db IIC T3 Gb
BExTBG05D	Ex db IIC T6 Gb			Ex db IIC T5 Gb		Ex db IIC T4 Gb
BExBGL1D	Ex db IIC T5 Gb					Ex db IIC T4 Gb

Annex 1 to: Certificate of Conformity IECEx DEK 10.0002X
EU-Type Examination Certificate KEMA 00ATEX2006 X, Issue 6
Report NL/KEM/ExTR10.0005/04

GAS						
Ambient temp.	-50 °C to +40 °C	-50 °C to +45 °C	-50 °C to +50 °C	-50 °C to +55 °C	-50 °C to +60 °C	-50 °C to +70 °C
BExBG05D-P(-SIL)		Ex db IIC T5 Gb				Ex db IIC T4 Gb
BExBG10D-P(-SIL)			Ex db IIC T4 Gb			Ex db IIC T4 Gb
BExBG15D-P(-SIL)			Ex db IIC T4 Gb			Ex db IIC T3 Gb
BExBG21D-P						Ex db IIC T3 Gb
BExTBG05D-P		Ex db IIC T5 Gb				Ex db IIC T4 Gb
BExBGL2D					Ex db IIC T6 Gb	Ex db IIC T5 Gb

DUST			
Ambient temp.	-50 °C to + 40 °C	-50 °C to +55 °C	-50 °C to +70 °C
BExBG05D(-SIL)	Ex tb IIIC T85 °C Db	Ex tb IIIC T100 °C Db	Ex tb IIIC T115 °C Db
BExBG10D(-SIL)	Ex tb IIIC T95 °C Db	Ex tb IIIC T110 °C Db	Ex tb IIIC T125 °C Db
BExBG15D(-SIL)	Ex tb IIIC T95 °C Db	Ex tb IIIC T110 °C Db	Ex tb IIIC T125 °C Db
BExBG21D		Ex tb IIIC T135 °C Db	Ex tb IIIC T200 °C Db
BExTBG05D	Ex tb IIIC T85 °C Db	Ex tb IIIC T100 °C Db	Ex tb IIIC T115 °C Db
BExBGL1D	Ex tb IIIC T95 °C Db	Ex tb IIIC T105 °C Db	Ex tb IIIC T120 °C Db
BExBG05D-P(-SIL)	Ex tb IIIC T90 °C Db	Ex tb IIIC T105 °C Db	Ex tb IIIC T120 °C Db
BExBG10D-P(-SIL)	Ex tb IIIC T120 °C Db	Ex tb IIIC T135 °C Db	Ex tb IIIC T150 °C Db
BExBG15D-P(-SIL)	Ex tb IIIC T120 °C Db	Ex tb IIIC T135 °C Db	Ex tb IIIC T150 °C Db
BExBG21D-P	Ex tb IIIC T150 °C Db	Ex tb IIIC T165 °C Db	Ex tb IIIC T180 °C Db
BExTBG05D-P	Ex tb IIIC T90 °C Db	Ex tb IIIC T105 °C Db	Ex tb IIIC T120 °C Db
BExBGL2D	Ex tb IIIC T60 °C Db	Ex tb IIIC T75 °C Db	Ex tb IIIC T90 °C Db