CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





LISTING No. 7136-2279:0504 Page 1 of 1

CATEGORY: 7136 -- AUDIBLE DEVICES FOR HAZARDOUS LOCATIONS

LISTEE: European Safety Systems LTDUnits 18 & 20, Impress House, Mansell Road, Acton, London,

W3 7QH, GB United Kingdom Contact: Alan King 44 20 8743 8880

Email: alan.king@e2s.com

DESIGN: Model D1x Loudspeakers. Model D1x Loudspeakers followed by L1 or L2, followed by -,

followed by V070, R008 or R016 may be used in Class I, Division 1, Groups A, B, C and D Hazardous Locations. Model D1x, followed by L1 or L2, followed by -, followed by V070, R008 or R016. Followed by -D may be used in Class II, Division 1, Groups F and G

Hazardous Locations.

Refer to listee's printed data sheet for additional detailed product description and operational

considerations.

RATING: Refer to listee's printed datasheet for electrical and environmental ratings.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as speaker for use in hazardous locations when used with separately listed

compatible fire alarm control units.

Refer to Manufacturers Installation Instruction Manual for details.

06-07-18 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: July 01, 2020 Listing Expires June 30, 2021

Authorized By: **DAVID CASTILLO**, M.E., F.P.E.

Fire Engineering Division