CERTIFICATE OF COMPLIANCE

Certificate Number 20170720-E230764

Report Reference E230764-20060401

Issue Date 2017-JULY-20

Issued to: EUROPEAN SAFETY SYSTEMS LTD

UNITS 18 & 20, IMPRESS HOUSE

MANSELL ROAD, ACTON

LONDON

W3 7QH UNITED KINGDOM

This is to certify that AUDIBLE-SIGNAL APPLIANCES FOR USE IN

representative samples of HAZARDOUS LOCATIONS

For Models Refer Addendum Page

Have been investigated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety: For Standards Refer Addendum Page

Additional Information: See the UL Online Certifications Directory at

www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC





CERTIFICATE OF COMPLIANCE

20170720-E230764 **Certificate Number** E230764-20060401 **Report Reference Issue Date** 2017-JULY-20

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Models:

Audible General Signalling Devices (Loudspeakers suitable for outdoor use): Models E2xL15FR008, E2xL15RR008, E2xL15FR016, E2xL15FR016, E2xL15FR070, E2xL15FR070, E2xL15FR100, E2xL15RR100, E2xL25FR008, E2xL25FR008, E2xL25FR016, E2xL25RR016, E2xL25FR070, E2xL25RR070, E2xL25FR100 and E2xL25RR100,

Models E2xL15UL8ohm, -16ohm, E2xL15UL70V Line, -100V Line, Models E2xL25UL8ohm, -16ohm, E2xL25UL70V Line, -100V Line.

For use in the following Hazardous Locations:

USL - Class I Division 2 Groups A, B, C and D; Class II Division 2 Groups F and G; Class I Zone 2 AEx nA IIC Tx Gc; Zone 22 AEx tc IIIC Tx Dc.

CNL - Class I Division 2 Groups A, B, C and D; Class II Division 2 Groups F and G; Ex nA IIC Tx Gc X; Ex tc IIIC Tx Dc X.

Tx - refer to 'TEMPERATURE RATING'.



North American Certification Program





CERTIFICATE OF COMPLIANCE

20170720-E230764 Certificate Number E230764-20060401 **Report Reference Issue Date** 2017-JULY-20

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Standards:

UL 1480A - Speakers for Commercial and Professional Use

ISA 12.12.01-2015 - Non-incendive Electrical Equipment for Use in Class I and II, Division 2 and Class III, division 1 and 2 Hazardous (Classified) Locations

UL 60079-0 - Explosive Atmospheres - Part 0: Equipment - General Requirements

UL 60079-15 - Explosive Atmospheres - Part 15: Equipment Protection by Type of Protection 'N'

UL 60079-31 - Explosive Atmosphere - Part 31: Equipment Dust Ignition Protection by Enclosure 'T'

UL 50 - Enclosures for Electrical Equipment

CSA C22.2 No. 205-12 - Signal Equipment, reaffirmed

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures Industrial Products

C22.2 No. 213-16 - Non-incendive electrical equipment for use in Class I and II, Division 2 and Class III, Divisions 1 and 2 hazardous (classified) locations

CSA C22.2 NO. 60079-0:15 - Explosive Gas Atmospheres - Part 0: General Requirements

CSA C22.2 NO. 60079-15:16 - Electrical Apparatus for Explosive Gas Atmospheres -- Part 15:

Construction, Test and Marking of Type of Protection 'N' Electrical Apparatus

CSA C22.2 NO 60079-31:15 - Explosive Atmosphere - Part 31: Equipment Dust Ignition Protection by Enclosure 'T'

CAN/CSA-C22.2 No. 94-M91 - Special Purpose Enclosures Industrial Products



North American Certification Program



