

Page 1 of 3

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: IECEx ULD 19.0007X Issue No: 0 Certificate history:

Issue No. 0 (2019-04-30)

Status: Current

Date of Issue: 2019-04-30

Applicant: European Safety Systems Limited

Impress House Mansell Rd.

Acton, London W3 7QH GB

United Kingdom

Equipment: GNExCP7 Call Point Switch, GNExCP7-PT-S / PM-S / PB-S / PT-D / PM-D / PB-D

Optional accessory:

Type of Protection: Flameproof "db", Dust Ignition Protection by Enclosure "tb"

Marking:

Ex db IIC T6...T5 Gb

Ex tb IIIC T90°C Db

-55°C to +70°C (T5) -55°C to +60°C (T6) -55°C to +70°C (T90°C)

Approved for issue on behalf of the IECEx

Certification Body:

Position: Senior Staff Engineer

Signature:

(for printed version)

Date: 2019-04-30

- 1. This certificate and schedule may only be reproduced in full.
- 2. This certificate is not transferable and remains the property of the issuing body.
- 3. The Status and authenticity of this certificate may be verified by visiting the Official IECEx Website.

Certificate issued by:

UL International DEMKO A/S Borupvang 5A, DK-2750 Ballerup Denmark



Katy A. Holdredge

Kety a. Holbridge



Certificate No: IECEx ULD 19.0007X Issue No: 0

Date of Issue: 2019-04-30 Page 2 of 3

Manufacturer: European Safety Systems Limited

Impress House Mansell Rd.

Acton, London W3 7QH GB

United Kingdom

Additional Manufacturing location(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2017 Explosive atmospheres - Part 0: Equipment - General requirements

Edition:7.0

IEC 60079-1: 2014-06 Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"

Edition:7.0

IEC 60079-31 : 2013 Explosive atmospheres - Part 31: Equipment dust ignition protection by enclosure "t"

Edition:2

This Certificate **does not** indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

DK/ULD/ExTR19.0007/00

Quality Assessment Report:

GB/SIR/QAR06.0020/07



Certificate No: IECEx ULD 19.0007X Issue No: 0

Date of Issue: 2019-04-30 Page 3 of 3

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

The GNExCP7 series Call Points are made from GRP material and provide Ex db and Ex tb types of protection. There are three variants, Push Button, Momentary Push Button and Push Button & Tool Reset. All models have a flanged flamepath for the cover and a cylindrical flamepath for the operating rods. All variants have three M20 x 1.5p threaded entries, two are located at the top of the base and one is located on the side of the base. The permitted orientations for the equipment are vertical only with the double cable entry uppermost or lowermost only.

Each variant may incorporate single or dual microswitch configurations, DIN rail mounted terminal blocks and PCB terminal. End of line and series monitoring resistors or diodes may be fitted when supplied at 24 or 48 Vdc.

Please see Annex for additional information.

SPECIFIC CONDITIONS OF USE: YES as shown below:

- No repair to the flameproof joints is permitted
- The equipment has a maximum capacitance of 6.33pF
- Equipment is permitted to be wall mounted only in the vertical position. The enclosure base is permitted in two mounting positions, with the double cable entry lowermost or uppermost.

Annex:

Annex to IECEx ULD 19.0007X Issue 0.pdf



Certificate No.: IECEx ULD 19.0007X

Issue No.: 0

Page 1 of 3

TYPE DESIGNATION

GNEx	CP7-	PB-	S
1	П	Ш	IV

I – Enclosure Series

GNEx - Primary Enclosure Series

II - Certifications

CP7- - Call Point 7

III - Type of Enclosure

PB- - Push Button

PM- - Momentary Push Button

PT- - Push Button & Tool Reset

IV - Switch configuration Width of Enclosure

S - Single microswitch

D - Dual microswitch

PARAMETERS RELATING TO THE SAFETY

Maximum Voltage =

250Vac max / 5.0A max (for units without any series resistor or end of line devices only)

48Vdc max / 1.0A max

24Vdc max / 3.0A max

Maximum Power = 6.224W

MARKING

GNExCP7-PT-*





Certificate No.: **IECEx ULD 19.0007X**

Issue No.: 0

Page 2 of 3

ATEX/IECEx: Ex db IIC T5 Gb (Ta -55°C to +70°C)

Ex db IIC T6 Gb (Ta -55°C to +60°C)

Ex db IIC T90°C Db (Ta -55°C to +70°C)

€ 0518

NEC/CEC CLASS / DIV:

Class | Div 2 Group ABCD T5 Ta -55°C to +70°C Class | Div 2 Group ABCD T6 Ta -55°C to +60°C Class II Dlv 2 Group FG T4 Ta -55°C to +70°C Class III Dlv 1 & 2 Ta -55°C to +70°C

NEC CLASS ZONE:

Class | Zone 1 AEx db ||C T5 Gb (Ta -55°C to +70°C) Class | Zone 1 AEx db ||C T6 Gb (Ta -55°C to +60°C) Zone 21 AEx tb IIIC T135°C Db (Ta -55°C to +70°C) CEC CLASS ZONE:

Class I Zone 1 Ex db IIC T5 Gb X (Ta -55°C to +70°C) Class I Zone 1 Ex db IIC T6 Gb X (Ta -55°C to +60°C) Zone 21 Ex tb |||C T135°C Db (Ta -55°C to +70°C)

GNExCP7-PB-* and GNExCP7-PM-*

GNExCP7-PB-D

CALL POINT

Input Voltage / Current; 48Vdc max 1A max / 24Vdc 3A max Input Voltage / Current; 250Vac 50/60Hz max 3,33A max

MARNINGS
USE COVER BOLTS CLASS AI-70
DO NOT OFFN WHEN AN EXPLOSIVE ATMOSPHERE IS PRESENT
POTENTIAL ELECTROSTATIC CHARGING HAZARD - SEE INSTRUCTIONS
FOR INDOOR OR OUTDOOR USE
TO REDUCE THE RISK OF IGNITION OF HAZARDOUS ATMOSPHERES, CONDUIT RUNS
MUST HAVE A SEALING FITTING CONNECTED WITHIN 18 INCHES OF CONDUIT

ALL ENTRIES M20x1.5 - IF TEMPERATURE EXCEEDS 60° C AT ENTRY OR 60° C AT BRANCHING POINT USE SUITABLY RATED CABLE AND CABLE GLANDS - SEE INSTRUCTIONS



European Safety

Impress, House, Mansell www.e2s.com Road, London W3 7QH UK



€ 0518

Class | Div 2 Group ABCD T5 Ta -55°C to +70°C Class | Div 2 Group ABCD T6 Ta -55°C to +60°C Class || Div 2 Group FG T4 Ta -55°C to +70°C

Class III Dlv 1 & 2 Ta -55°C to +70°C

NEC CLASS ZONE:

Class | Zone 1 AEx db | C T5 Gb (Ta -55°C to +70°C)

Class I Zone 1 AEx db IIC T6 Gb (Ta -55°C to +60°C) Zone 21 AEx tb IIIC T135°C Db (Ta -55°C to +70°C)

CEC CLASS ZONE:

Class I Zone 1 Ex db IIC T5 Gb X (Ta -55°C to +70°C)

Class | Zone 1 Ex db ||C T6 Gb X (Ta -55°C to +60°C) Zone 21 Ex tb |||C T135°C Db (Ta -55°C to +70°C)

WARNINGS:

USE COVER BOLTS CLASS A4-70 DO NOT OPEN WHEN AN EXPLOSIVE ATMOSPHERE IS PRESENT POTENTIAL ELECTROSTATIC RISK - SEE INSTRUCTIONS



Certificate No.: IECEx ULD 19.0007X

Issue No.: 0 Page 3 of 3

ROUTINE EXAMINATIONS AND TESTS

Routine tests according to IEC 60079-1, cl. 16 are not required, as the enclosures have been successfully tested at four times the reference pressure.