

8	9	10
ISSUE	MOD No.	INITIAL/DATE
1		Introduction DAH 23-07-2020

(REF 60,0 ONLY)

D1xB2X15DC024
D1xB2 Xenon Beacon
Nominal Voltage: 24V dc Voltage Range: 20-28V dc
Nominal Current: 835mA

ATEX / IECEx
Ex db IIC T3 Gb Ta -55°C to +80°C
Ex db IIC T4 Gb Ta -55°C to +65°C
Ex tb IIIC T132°C Db Ta -55°C to +80°C

II 2G
II 2D

NEC / CEC Class / Div
Class I Div 1 Group ABCD T3C Ta -55°C to +80°C
Class I Div 1 Group ABCD T4 Ta -55°C to +55°C
Class II Div 1 Group EFG T4 Ta -55°C to +80°C
Class III Div 1 Ta -55°C to +80°C

NEC Class / Zone
Class I Zone 1 AEx db IIC T3 Ta -55°C to +80°C
Class I Zone 1 AEx db IIC T4 Ta -55°C to +65°C
Zone 21 AEx tb IIIC T132°C Ta -55°C to +80°C

CEC Class / Zone
Ex db IIC T3 Ta -55°C to +80°C
Ex db IIC T4 Ta -55°C to +65°C
Ex tb IIIC T132°C Ta -55°C to +80°C

Location: Suitable for indoor and outdoor use
If temperature exceeds 60°C at entry or 60°C at branching point
use suitably rated cable and cable gland - see instructions
Visual Signalling Appliance for use in Hazardous Locations
Visual Signalling Appliance for use in Fire Alarm Systems - Private Mode
Serial Number: YY101DB320000X
Impress House, Mansell Rd, London UK W3 7QH www.e2s.com

INSTRUCTION SHEET D191-00-201-IS
IP66 Type 4/4X/3R/13
3/4"NPT M20
M20 3/4"NPT
Cable Entries: 2x off M20 x 1.5mm / 3 x off 3/4" NPT

2S warning signals
CE 2813
UL CERTIFIED E243313

D1XB2X15DC024

D1xB2X15AC115
D1xB2 Xenon Beacon
Nominal Voltage: 115V ac Voltage Range: 110-120V ac
Nominal Current: 310mA

ATEX / IECEx
Ex db IIC T3 Gb Ta -55°C to +70°C
Ex db IIC T4 Gb Ta -55°C to +65°C
Ex tb IIIC T153°C Db Ta -55°C to +70°C

II 2G
II 2D

NEC / CEC Class / Div
Class I Div 1 Group ABCD T4 Ta -55°C to +70°C
Class I Div 1 Group ABCD T4A Ta -55°C to +55°C
Class II Div 1 Group EFG T4 Ta -55°C to +40°C
Class III Div 1 Ta -55°C to +40°C

NEC Class / Zone
Class I Zone 1 AEx db IIC T3 Ta -55°C to +70°C
Class I Zone 1 AEx db IIC T4 Ta -55°C to +65°C
Zone 21 AEx tb IIIC T153°C Ta -55°C to +70°C

CEC Class / Zone
Ex db IIC T3 Ta -55°C to +70°C
Ex db IIC T4 Ta -55°C to +65°C
Ex tb IIIC T153°C Ta -55°C to +70°C

Location: Suitable for indoor and outdoor use
If temperature exceeds 60°C at entry or 60°C at branching point
use suitably rated cable and cable gland - see instructions
Visual Signalling Appliance for use in Hazardous Locations
Serial Number: YY101DB350000X
Impress House, Mansell Rd, London UK W3 7QH www.e2s.com

INSTRUCTION SHEET D191-00-201-IS
IP66 Type 4/4X/3R/13
3/4"NPT M20
M20 3/4"NPT
Cable Entries: 2x off M20 x 1.5mm / 3 x off 3/4" NPT

2S warning signals
CE 2813
UL CERTIFIED E243313

D1XB2X15AC115

D1xB2X15DC048
D1xB2 Xenon Beacon
Nominal Voltage: 48V dc Voltage Range: 42-54V dc
Nominal Current: 330mA

ATEX / IECEx
Ex db IIC T3 Gb Ta -55°C to +80°C
Ex db IIC T4 Gb Ta -55°C to +65°C
Ex tb IIIC T132°C Db Ta -55°C to +80°C

II 2G
II 2D

NEC / CEC Class / Div
Class I Div 1 Group ABCD T3C Ta -55°C to +80°C
Class I Div 1 Group ABCD T4 Ta -55°C to +55°C
Class II Div 1 Group EFG T4 Ta -55°C to +80°C
Class III Div 1 Ta -55°C to +80°C

NEC Class / Zone
Class I Zone 1 AEx db IIC T3 Ta -55°C to +80°C
Class I Zone 1 AEx db IIC T4 Ta -55°C to +65°C
Zone 21 AEx tb IIIC T132°C Ta -55°C to +80°C

CEC Class / Zone
Ex db IIC T3 Ta -55°C to +80°C
Ex db IIC T4 Ta -55°C to +65°C
Ex tb IIIC T132°C Ta -55°C to +80°C

Location: Suitable for indoor and outdoor use
If temperature exceeds 60°C at entry or 60°C at branching point
use suitably rated cable and cable gland - see instructions
Visual Signalling Appliance for use in Hazardous Locations
Serial Number: YY101DB360000X
Impress House, Mansell Rd, London UK W3 7QH www.e2s.com

INSTRUCTION SHEET D191-00-201-IS
IP66 Type 4/4X/3R/13
3/4"NPT M20
M20 3/4"NPT
Cable Entries: 2x off M20 x 1.5mm / 3 x off 3/4" NPT

2S warning signals
CE 2813
UL CERTIFIED E243313

D1XB2X15DC048

D1xB2X15AC230
D1xB2 Xenon Beacon
Nominal Voltage: 230V ac Voltage Range: 220-240V ac
Nominal Current: 170mA

ATEX / IECEx
Ex db IIC T3 Gb Ta -55°C to +70°C
Ex db IIC T4 Gb Ta -55°C to +65°C
Ex tb IIIC T153°C Db Ta -55°C to +70°C

II 2G
II 2D

NEC / CEC Class / Div
Class I Div 1 Group ABCD T4 Ta -55°C to +70°C
Class I Div 1 Group ABCD T4A Ta -55°C to +55°C
Class II Div 1 Group EFG T4 Ta -55°C to +40°C
Class III Div 1 Ta -55°C to +40°C

NEC Class / Zone
Class I Zone 1 AEx db IIC T3 Ta -55°C to +70°C
Class I Zone 1 AEx db IIC T4 Ta -55°C to +65°C
Zone 21 AEx tb IIIC T153°C Ta -55°C to +70°C

CEC Class / Zone
Ex db IIC T3 Ta -55°C to +70°C
Ex db IIC T4 Ta -55°C to +65°C
Ex tb IIIC T153°C Ta -55°C to +70°C

Location: Suitable for indoor and outdoor use
If temperature exceeds 60°C at entry or 60°C at branching point
use suitably rated cable and cable gland - see instructions
Visual Signalling Appliance for use in Hazardous Locations
Serial Number: YY101DB330000X
Impress House, Mansell Rd, London UK W3 7QH www.e2s.com

INSTRUCTION SHEET D191-00-201-IS
IP66 Type 4/4X/3R/13
3/4"NPT M20
M20 3/4"NPT
Cable Entries: 2x off M20 x 1.5mm / 3 x off 3/4" NPT

2S warning signals
CE 2813
UL CERTIFIED E243313

D1XB2X15AC230

RELATED DRAWING

No modification permitted
without reference to the
"Authorised Person"

DRAWING TO BS8888:2000
GEOMETRIC TOLERANCES TO ISO1101:1983
LINEAR DIMENSIONAL TOLS +/-0.35mm
ANGULAR DIMENSIONAL TOLS +/-2 deg

STANDARDS
D1xB2

DRAWN	DATE
D.HOWGILL	23-07-2020
CHECKED	DATE
R.N.POTTS	23-07-2020
APPROVED	DATE
R.N.POTTS	23-07-2020

SURFACE FINISH	WEIGHT (Kg)
MATERIAL	
ALTERNATIVE MATERIAL	

THIS DRAWING AND ANY INFORMATION OR DESCRIPTIVE
MATTER THEREIN IS COMMUNICATED IN CONFIDENCE AND IS
THE COPYRIGHT PROPERTY OF EUROPEAN SAFETY SYSTEMS
LTD. NEITHER THE WHOLE OR ANY EXTRACT MAY BE
DISCLOSED, LOANED, COPIED OR USED FOR MANUFACTURING
OR TENDERING PURPOSES WITHOUT THEIR WRITTEN
CONSENT.

© EUROPEAN SAFETY SYSTEMS LTD.
AS PER LATEST DATE OF ISSUE SHOWN ABOVE

EUROPEAN SAFETY SYSTEMS LTD
IMPRESS HOUSE
MANSELL ROAD
ACTON
LONDON W3 7QH
WWW.E2S.COM

ALL DIMENSIONS IN MM IF IN DOUBT, ASK - DO NOT SCALE		A3
TITLE D1xB2X15 BEACON PRODUCT LABEL		
SCALE 1:1	SHEET 1 of 1	DRAWING NUMBER D191-09-215